



Grid Harmonization & Building Decarbonization CANNOT be Separate Topics



Ted M. Tiffany
LEED AP BD&C
Principal
Director of Sustainability

DECARBONIZATION POLICY PUSH

- **By 2020:** return GHGs to 1990 levels (*AB 32, 2006*)
- **By 2030:** 40% below 1990 levels (*SB 32, 2015*)
- **By 2050:** 80% below 1990 levels (*Executive Orders B-30-15 and S-3-05*)
- **And now...By 2045:** 100% zero-carbon electricity (*SB 100*) and *carbon neutral economy-wide* (*Executive Order B-55-18*)



DECARBONIZATION POLICY PUSH

- It's simple! Design for Electrification and we're done right?
- Earth is **SAVED!**
- **NOT** So simple to Decarb Electricity on the Grid
- Time of Consumption is Critically Important to Emissions



Sonoma Clean Power Headquarters

- Building Electrification Retrofit
- 15,000 SF Two Story Office
- Eliminated "Natural" Gas on site
- High Efficiency Variable Speed Rooftop Heat Pumps
- Smart VAV diffusers
- On-site Solar 30kW
- 150 kWh Stationary Battery storage
- 23 Electric Car Charging Stations
- Automatic, grid-sigaled HVAC, lighting and plug load demand reduction
- NBI Grid Optimal Pilot
- Estimated completion 2020

GRIDOPTIMAL™
BUILDINGS INITIATIVE




The Challenge: All-Electric Retrofit Design & Demonstrate Grid Harmonization based on Carbon

Sonoma Clean Power Headquarters

- Building retrofit with high efficiency rooftop heat pumps
- Smart VAV diffusers
- On-site solar, stationary battery storage, car charging
- NBI Grid Optimal Pilot
- Automatic, grid-sigaled HVAC, lighting and plug load demand reduction
- Estimated completion 2020

23 Car Charging Stations



150 kWh Stationary Battery



Sonoma Clean Power Headquarters:
Static Carbon Accounting




SCP's Power Sources

2017 Emission Factor:
CleanStart - 127.98 lb CO₂/MWh
EverGreen - 53.00 lb CO₂/MWh



Static Carbon multipliers are easy & accessible BUT not useful for Time of Use or Grid Harmonization




USEPA, eGRID, June 2018
Crosshatching indicates that an area falls within overlapping eGRID subregions due to the presence of multiple electric service providers. Visit Power Profiler to definitively determine the eGRID subregion associated with your location and electric service provider.
<http://www.epa.gov/energy/power-profiler>

Sonoma Clean Power Headquarters: Hourly Carbon Accounting Emission Sources




Sonoma Clean Power Headquarters: Hourly MARGINAL Carbon Accounting Emission Sources

Marginal Carbon Emissions Coverage



- Grid Market
- (All)
 - Europe: ENTSO-E
 - USA: Retail Electric Power Markets
 - USA: Wholesale Electric Power Mar...
- Grid Name
- (All)


Sonoma Clean Power Headquarters: Hourly LONG RANGE MARGINAL Carbon Accounting Emission Sources



Sonoma Clean Power Headquarters: Which Hourly Emission Factor Is BEST?




- Marginal emission rates are best for project planning and carbon mitigation strategies
- LONG Range Marginal emission rates (30 Year Planning) good for life cycle carbon emissions of buildings or long range policy development



Sonoma Clean Power Headquarters: Design Modeling

- Traditional Modeling Tools Designed for optimizing energy and cost = NO Connection to Carbon
- Energy & Building Performance tools NOT Connected to Renewable and Storage tools automatically
- Charge Charging Stations NOT modeled in tools easily or modeling the dynamic nature



Energy Use, Cost, and Savings					
Energy Conservation Measure No.	Annual Electricity Usage (kWh/yr)	Renewable Energy Production (kWh/yr)	Renewable Energy Offset (% of Electricity)	Net Annual Energy Cost With PV (\$)	Annual Energy Cost Savings of Measure (\$)
Base Case	167,080	41,295	25%	\$ 32,468	N/A
ECM-1 Temperature Setback	162,670	41,295	26%	\$ 31,348	\$ 1,120
ECM-2 Lighting Demand Response	165,470	41,295	25%	\$ 32,048	\$ 420
ECM-3 Interoperable Thermostats	166,890	41,295	26%	\$ 29,908	\$ 2,560
ECM-4 ECM-1+ Easy winter warm up	162,360	41,295	26%	\$ 31,278	\$ 1,190
ECM-5 Bundle of ECM's from 1-4	150,620	41,295	27%	\$ 28,588	\$ 3,910
ECM-5 Plus 150 kWh Battery	150,620	41,295	27%	\$ 26,244	\$ 6,224
ECM-5 Plus 400 kWh Battery	150,620	41,295	27%	\$ 26,234	\$ 6,234
ECM-5 Plus 600 kWh Battery	150,620	41,295	27%	\$ 26,251	\$ 6,217


Sonoma Clean Power Headquarters:

PGE/SCP A6 TOU Rate

- Winter Peak rates fall outside of building warm up period, NOT aligned with carbon
- Maintaining building temperature and “gentle winter warm up” a key strategy
- Utilizing battery storage early morning a carbon savings advantage

Time-of-Use: Winter Rates

Winter rates are in effect November through April.



Winter Warm Up Carbon Peaking

	Base	ECM-1	ECM-2	ECM-3	ECM-4	ECM-5	150 kWh Battery	400kWh Battery	600 kWh Battery
1/1/2019 22:00	3.9	5.3	5.3	4.8	5.3	4.8	2.0	2.0	2.0
1/1/2019 23:00	16.5	12.3	12.3	10.5	12.3	10.5	13.2	2.3	2.3
1/2/2019 0:00	0.7	5.1	5.1	6.8	5.1	6.8	20.9	16.8	15.7
1/2/2019 1:00	17.5	17.7	17.7	16.1	17.7	16.1	19.3	15.4	14.4
1/2/2019 2:00	0.7	0.7	0.7	2.3	0.7	2.3	19.3	15.6	14.5
1/2/2019 3:00	17.3	17.3	17.3	15.5	17.3	15.5	18.8	15.1	14.1
1/2/2019 4:00	12.1	12.1	12.1	14.0	23.4	19.8	19.2	15.6	14.4
1/2/2019 5:00	18.7	18.7	18.7	16.6	30.8	24.6	20.3	16.6	15.2
1/2/2019 6:00	40.9	36.7	36.6	26.7	32.9	25.9	21.3	17.4	16.4
1/2/2019 7:00	40.4	36.4	36.4	27.4	33.6	26.5	21.9	17.9	16.8
1/2/2019 8:00	38.5	36.4	36.3	27.4	33.8	27.0	22.0	18.0	16.9
1/2/2019 9:00	35.9	36.3	36.2	27.4	33.6	26.6	22.0	21.1	16.8
1/2/2019 10:00	19.0	23.7	23.7	20.9	23.5	20.8	21.8	17.5	16.2
1/2/2019 11:00	13.2	17.8	17.8	15.5	17.7	15.4	21.5	17.3	16.1
1/2/2019 12:00	15.9	18.2	18.2	18.3	18.9	17.4	20.9	16.7	15.6
1/2/2019 13:00	16.1	16.1	16.1	14.3	16.0	14.1	20.9	16.7	15.6
1/2/2019 14:00	16.7	16.7	16.7	15.1	16.7	14.9	21.9	17.5	16.3
1/2/2019 15:00	14.4	14.4	14.4	12.8	14.4	12.8	23.0	18.4	17.2
1/2/2019 16:00	15.2	20.2	20.2	18.7	20.1	18.7	24.3	20.2	18.8
1/2/2019 17:00	12.7	18.3	18.3	16.3	18.3	16.2	16.2	23.2	21.6
1/2/2019 18:00	11.4	17.2	17.2	14.6	17.2	14.6	14.6	23.7	22.1
1/2/2019 19:00	35.6	37.2	37.2	33.9	36.9	33.8	28.7	23.4	21.9
1/2/2019 20:00	35.9	35.9	35.9	32.7	35.7	32.7	28.2	23.0	21.5

Sonoma Clean Power Headquarters:

PGE/SCP A6 TOU Rate

- Time of Use Rates NOT Aligned with Carbon on the Grid with this office occupancy, exacerbated by hotel/motel, restaurant occupancy types
- Solar and battery storage deployment shifts to later day "ramping period" outside CURRENT on peak rate time

Time-of-Use: Summer Rates

Summer rates are in effect May through October.




Summer Afternoon Carbon Peaking

	Base	ECM-1	ECM-2	ECM-3	ECM-4	ECM-5	150 kWh Battery	400kWh Battery	600 kWh Battery
8/7/2019 0:00	2.9	0.7	0.7	0.7	0.7	0.7	9.2	9.2	9.2
8/7/2019 1:00	0.7	0.7	0.7	0.7	0.7	0.7	8.6	8.6	8.6
8/7/2019 2:00	0.7	0.7	0.7	0.7	0.7	0.7	8.5	8.5	8.5
8/7/2019 3:00	0.7	0.7	0.7	0.7	0.7	0.7	8.6	8.6	8.6
8/7/2019 4:00	1.3	1.3	1.3	1.3	1.3	1.3	7.4	9.0	9.0
8/7/2019 5:00	8.7	8.6	8.7	7.8	8.6	7.3	7.3	9.3	9.3
8/7/2019 6:00	10.8	10.9	10.8	9.4	10.9	9.5	9.5	9.6	9.6
8/7/2019 7:00	14.5	15.4	14.5	14.6	15.4	15.4	9.7	9.7	9.7
8/7/2019 8:00	11.7	12.3	11.6	11.7	12.3	12.5	8.8	8.8	8.8
8/7/2019 9:00	13.9	14.8	13.9	13.0	14.8	13.7	8.5	8.5	8.5
8/7/2019 10:00	16.5	17.2	16.4	14.3	17.2	14.8	8.8	8.8	8.8
8/7/2019 11:00	16.0	16.6	15.9	13.6	16.6	14.2	8.9	8.9	8.9
8/7/2019 12:00	19.0	19.6	17.5	16.4	19.6	16.0	9.5	9.5	9.5
8/7/2019 13:00	22.1	9.9	20.5	19.7	9.9	11.2	9.8	9.8	9.8
8/7/2019 14:00	25.1	22.7	22.3	21.4	22.7	18.2	10.6	10.6	10.6
8/7/2019 15:00	29.5	24.5	24.0	23.0	24.5	21.0	11.5	11.5	11.5
8/7/2019 16:00	19.1	25.7	25.0	24.0	25.7	20.3	11.9	11.9	11.9
8/7/2019 17:00	19.3	25.1	26.2	25.2	25.1	19.5	12.9	12.4	12.4
8/7/2019 18:00	22.8	27.7	27.8	26.6	27.7	23.4	22.8	13.3	13.3
8/7/2019 19:00	25.1	22.8	29.1	26.0	22.8	19.2	18.6	13.6	13.6
8/7/2019 20:00	17.4	14.5	20.9	16.5	14.5	12.6	13.4	13.4	13.4
8/7/2019 21:00	9.1	1.9	1.9	1.9	1.9	1.9	12.9	12.9	12.9
8/7/2019 22:00	7.5	0.9	0.9	0.9	0.9	0.9	11.7	11.7	11.7


Design Optimization: Winter Weekday

- Utilize Battery Storage for building warm up
- Prioritize building warm up and maintain building temps overnight
- Charge Batteries after winter ramping period




Design Optimization: Summer Weekday

- Utilize Battery Storage for afternoon ramping period
- Prioritize self utilization or storage of on-site generation
- Mitigate Building loads in ramping period, temp setback, lighting dimming, etc.



GRIDOPTIMAL
BUILDINGS INITIATIVE

Design Optimization: Summer



GRIDOPTIMAL
BUILDINGS INITIATIVE

Optimization Challenge



ADR Automated Demand Response Program

PG&E Pacific Gas and Electric Company


\$\$\$\$\$\$



Basis of Design : System Control Architecture




Proposed Approach



Proposed Approach

Carbon Value	Demand Charge Management Savings	Energy Arbitrage Savings	GHG Impact
\$0/metric ton	\$3,112/year	\$158/year	15 metric tons INCREASE/year
\$15/metric ton	\$3,112/year	\$158/year	10 metric tons INCREASE/year
\$65/metric ton	\$3,112/year	\$47/year	8 metric tons INCREASE/year
\$150/metric ton	\$3,112/year	-\$53/year	7 metric tons INCREASE/year
\$1000/metric ton	\$2,220/year	\$63/year	1 metric ton DECREASE/year
\$2000/metric ton	\$904/year	\$145/year	8 metric tons DECREASE/year

From a study by Enel X on impacts of adding cost of carbon assumptions to a microgrid financial model



Lessons Learned:

- Key To Everything is COST of CARBON
 - Either align utility rates to Carbon on the grid (3-5yr process with CPUC/Utilities OR
 - Include the high cost of Carbon to the financial equations
 - Rates need to adapt to reward self utilization of on site renewable power first before seeking low carbon energy on the grid
- Design tools need to be enabled with:
 - PV and battery storage sizing tools
 - Marginal Emission rates need to be accessible like weather files for different grid regions
 - Utility rate adders for cost of Carbon should be easily added

